

Tasks to Complete	Responsible Person	Projected Completion Date	Suggestions	Estimated Cost
<ol style="list-style-type: none">1. Post directional signage indicating the location of the accessible entrance.2. Modify the accessible tables to provide adequate knee space.3. Modify pathway inside accessible rooms to 36 inches wide.4. Install auditory and visible indicators for emergency notification system in accessible rooms.		Completion date contingent on budget decisions.	Accessible rooms need to be accessible for any type of disability.	